

LOCATION 2633 Birchwood Dr. Ct. CITY CASPER
BETWEEN Anthony Dr. STREET & Dead End. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	125'	2-10-95		
MAIN TO PROP. LINE	3/4"	P	3'			
PROP. LINE TO BLDG.	3/4"	P	122'			

ENTERS: 2633 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 418" W of center of Anthony Dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S Hyatt
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1978
DEPTH: 3 Ft. _____ In. LOCATION 23' S. of center of Birchwood Dr

"A" P/S READING 1.6 TOTAL ANODES 1* 0 17* 0 L.R. # 63671

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY