

LOCATION 1601 Blackwood St. CITY Gastonia

BETWEEN Upton St. STREET & Garland Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>92'</u>	<u>5-8-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>87'</u>			

ENTERS 1601 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W/C LOCATION 157' SW. of center  
Blackwood St.


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.C.

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED       

DEPTH 3 FT 0 IN LOCATION 16' SE. of center of Upton St.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 579675

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	