


LOCATION <u>408 Bolding St</u>		CITY <u>GASTONIA</u>	
BETWEEN <u>BARNICK ST</u>		STREET & STREET	
	SIZE	TYPE	LENGTH
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>100'</u>
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>40'</u>
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>60'</u>
ENTERS <u>408</u>		BRANCHED INTO	
TAP SIZE <u>1/2</u>	PRESSURE <u>60</u> PSI	INCHES W C	LOCATION <u>170' N. of center of Barnick St</u>
PRESSURE TEST @ <u>100</u> PSI FOR <u>1 1/4</u> HRS BY <u>S.H.</u>			
MAIN-SIZE <u>2"</u>	C I	BARE STEEL	COATED STEEL
DEPTH <u>3 FT</u>	0 IN	LOCATION <u>12' W. of center of Bolding St.</u>	PLASTIC <input checked="" type="checkbox"/> YEAR INSTALLED <u>1989</u>
"A" P/S READING <u>P</u>		TOTAL ANODES 1# <u>0</u> 17# <u>0</u>	LR # <u>83275</u>
REMARKS			



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	