

LOCATION 127 Bounty Ln. CITY GASTONIA
BETWEEN Robinson Rd. STREET & Eagles Walk Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>158'</u>	<u>11-5-98</u>		
MAIN TO PROP. LINE	<u>3/4'</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG	<u>3/4'</u>	<u>P</u>	<u>113'</u>			

ENTERS 127 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 150' W. of center of
Bounty Ln.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. H. H. H. H. H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 13' N. of center of Eagles Walk Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 2156107

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY