

LOCATION 224 N. Boyce St. CITY GASTONIA  
BETWEEN Rankin St. STREET & Airline Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>85'</u>		<u>3-5-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>48'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>37'</u>			

ENTERS: 224 N. Boyce St. BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 69' East of Boyce St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ml  
MAIN-SIZE 21" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996  
DEPTH: 3 FT. 0 IN. LOCATION East of Boyce St.

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

	Test Station		ENG. DEPT. USE ONLY
	Reading & Location	Lead	
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	