

LOCATION 224 N. Boyce St. CITY CASTONIA
BETWEEN Rankin St. STREET & Airline Ave STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>		<u>84' of 3/4" c/w 3-5-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>66'</u>			

ENTERS: 224 N. Boyce St. BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 14' East of Boyce

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY my
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT. 0 IN. LOCATION East side of Boyce St.

"A" P/S READING P TOTAL ANODES 1# ✓ 17# _____ L.R. # _____

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		