


LOCATION 625 N. BoyceCITY GastoniaBETWEEN AllisonSTREET & Lincoln

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>47'</u>	<u>2-2-95</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>42</u>			

ENTERS: 625BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 159' S of C of AllisonPRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995DEPTH: 3 Ft. _____ In. LOCATION 16' W of C of Boyce"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # 573897

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY