

LOCATION 907 N. Boyce

CITY GASTONIA

BETWEEN NORMENT

STREET & DAVISON

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P.	3' used To	11-12-91		
MAIN TO PROP. LINE			TIE-OVER P.			
PROP. LINE TO BLDG.			SEV. TO NEW MAIN			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 162' N. of C of DAVISON


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1991

DEPTH: 3 Ft. 6 In. LOCATION 9' west of Boyce

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY