

LOCATION 1003 N. Boyce CITY Gastonia
BETWEEN Norment STREET & Lenox STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>5' 3/4 Plastic</u>	<u>11-13-91</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>used to Tie-over</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>to MAIN</u>			

ENTERS: BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 104 North of
center of Norment


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. In. LOCATION 12' West of center of Boyce

"A" P/S READING TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY