

LOCATION 1203 N. Boyce ST CITY CASSTON

BETWEEN W. Lenox STREET & Sycamore ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>21'</u>		<u>9-</u>	<u>13-97</u>
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>11'</u>			

ENTERS: 1203 BRANCHED INTO:

TAP SIZE. 3/4" PRESSURE 60 PSI INCHES W C LOCATION 63' W. of center of N. Boyce ST

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. H. N. S. H.

MAIN-SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 2 FT. 0 IN LOCATION 100' N. of center of W. Lenox ST

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 420227

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	S		
P/S Pipeline Lead - White Existing Main	E		

