

LOCATION 1208 N. Boyce St. CITY Gastonia
BETWEEN Lennox STREET & Seymour STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>66'</u>	<u>11-16-91</u>		
MAIN TO PROP. LINE	<u>1/1</u>	<u>11</u>	<u>28'</u>			
PROP. LINE TO BLDG.	<u>1</u>	<u>1/1</u>	<u>38'</u>			

ENTERS: 1208

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 13' W. of cot


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY AP Boyle

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY