

LOCATION 1301 N. Boyce St. CITY Gastonia  
BETWEEN Sycamore Ave STREET & N. Morris STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>21'</u>		<u>C+W Service to be Retired</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>1'</u>		<u>with main. Purged with</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>20'</u>		<u>air + capped</u>	

ENTERS: 1301 N. Boyce St BRANCHED INTO: \_\_\_\_\_  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 13' west of N. Boyce St  
55' North of Sycamore Ave


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY B.B.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 6 IN LOCATION 13' west of N. Boyce St.

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS Renewed Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY