

LOCATION 1205 N. Boyer St CITY Castroville
BETWEEN W. Leavitt St STREET & Sycamore St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>49'</u>			<u>9-13-97</u>
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>49'</u>			


ENTERS: 1205 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 121' N. of center of
W. Leavitt St

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huffstetter
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 4 FT. 0 IN. LOCATION 17' W. of center of N. Boyer St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 620227

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY