

LOCATION 401 S Boyd St

CITY Gastonia

BETWEEN Garrison Blvd

STREET &

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|---------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4' | Plastic | 20' | | | 11/5/94 |
| MAIN TO PROP. LINE | 3/4' | | 6' | | | |
| PROP. LINE TO BLDG. | 3/4" | | 14' | | | |

ENTERS: 401

BRANCHED INTO:

TAP SIZE: 3/8"

PRESSURE 60 P.S.I. _____ INCHES W.C.

LOCATION North side of 401

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 10" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1969

DEPTH: 3 Ft. 0 In.


LOCATION South side of Garrison Blvd

"A" P/S READING .90

TOTAL ANODES 1*0 17*0

L.R. # 498302

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY