

LOCATION 403 S Boyd st CITY GASTONIA  
BETWEEN Garrison Blvd STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	Plastic	123'			11/5/94
MAIN TO PROP. LINE	3/4"		34'			
PROP. LINE TO BLDG.	3/4"		89'			

ENTERS: 403 BRANCHED INTO:  
TAP SIZE: 3/8" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION South side of 403

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By DT  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1967  
DEPTH: 2 Ft. 6 In. LOCATION East side of S Boyd st

"A" P/S READING .90 TOTAL ANODES 1# 0 17# 0 L.R. # 498302

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY