


LOCATION 100 + 102 E Bradley CITY GASTONIABETWEEN BRADLEY STREET & HARRISON STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>		<u>TIED OVER</u>		
MAIN TO PROP. LINE				<u>1-14-97</u>		
PROP. LINE TO BLDG.						

ENTERS: 100 + 102 BRANCHED INTO: 700 + 702TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M PARKERMAIN-SIZE 8" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL X PLASTIC \_\_\_\_\_ YEAR INSTALLED 96DEPTH: 3 FT. 0 IN. LOCATION 17' E OF N Marietta"A" P/S READING 1.4 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_REMARKS:  
  
  
  


Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-RISERS</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY