

LOCATION

208 W. Bradley Ave

CITY CAST.

BETWEEN

N. York St.

STREET &

DEAD END

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	47'			2-16-96
MAIN TO PROP. LINE	11	"	4'			
PROP. LINE TO BLDG.	11	"	43'			

ENTERS:

Same

BRANCHED INTO:

TAP SIZE:

3/4"

PRESSURE

60

PSI

INCHES W.C.

LOCATION

320' East from @ of
N. York St.

PRESSURE TEST: @

100

PSI

FOR

1/4

HRS.

BY

mf

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1996

DEPTH:

3 FT.

0

IN.

LOCATION

N. SIDE OF W. BRADLEY AVE.

"A" P/S READING


P

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E

ENG. DEPT. USE ONLY