

LOCATION 210 W. Bradley Ave CITY Cast.

BETWEEN N. York St. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>39'</u>			<u>8-18-96</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>34'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 278' East from @ of N. York St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY mm

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION N. Side of W. Bradley Ave

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY