

LOCATION 3924 Branding Iron Dr. CITY Gastonia

BETWEEN Buckskin Dr. STREET & Lewis Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>82'</u>	<u>4-2-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>72'</u>			

ENTERS: 3904 BRANCHED INTO

TAP SIZE. 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 340' SE. of center of Buckskin Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hufstetter

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1979

DEPTH: 3 FT 0 IN LOCATION 15' NE of center of Branding Iron Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 207884

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY