

LOCATION 3500 Brentwood Dr CITY Gastonia

BETWEEN Country Club Dr STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>155'</u>	<u>8-9-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>75'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS 3500 BRANCHED INTO _____

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 160' N. of center of Country Club Dr


PRESSURE TEST @ 600 PSI FOR 1/4 HRS BY S.G.

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1985

DEPTH 2 FT 0 IN LOCATION 48' w. of center of Brentwood Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 698370

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	