

LOCATION 3601 Bentwood Dr. CITY Easton

BETWEEN Kendrick Rd STREET & Sherwood Cir STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>138</u>	<u>11-8-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>43</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>95</u>			

ENTERS: 3601 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Spade House


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bennett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1981

DEPTH: 2 Ft. 6 In. LOCATION 13' E of C&A

"A" P/S READING .90 TOTAL ANODES 1* _____ 17* _____ L.R. # 00503702

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY