


LOCATION 3636 Brentwood Dr.CITY GastoniaBETWEEN Kendrick Rd.STREET & Sheerwood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	122'	3-15-94		
MAIN TO PROP. LINE	3/4	P	12'			
PROP. LINE TO BLDG.	3/4	P	110'			

ENTERS: 3636BRANCHED INTO: 0TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION S Side of 3636PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1981DEPTH: 3 Ft. In. LOCATION 16' E of C of Brentwood"A" P/S READING 295 TOTAL ANODES 1# - 17# - L.R. # 94034

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY