


LOCATION 602 BRIARCLIFF RDCITY CANTONIABETWEEN UNION RDSTREET & SPRINGWAY DR

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>123'</u>	<u>12-2-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>34'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>89'</u>			

ENTERS: 602BRANCHED INTO: 0TAP SIZE: 3/8PRESSURE 60 PSI 0 INCHES W.C.LOCATION 153' S OF C OF UNION RD.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY R.R.MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL / PLASTIC YEAR INSTALLED 1964DEPTH: 3 FT 0 IN. LOCATION 14' E OF C OF BRIARCLIFF RD."A" P/S READING 1.3TOTAL ANODES 1# 0 17# 0L.R. # 00683741

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

ENG. DEPT. USE ONLY