

LOCATION 504 Bridge St. CT. CITY Castaña

BETWEEN Patrick Rd STREET & Cut-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>112'</u>	<u>10-28-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>72'</u>			

ENTERS: 504 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 185' W. of center of Patrick Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hultsletty

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION 18' S. of center of Bridge St. CT.

"A" P/S READING 7 TOTAL ANODES 1# 0 17# 0 L.R. # 580705

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY