

LOCATION SIO Bridge Stn CT CITY Castroville

BETWEEN Patrick Rd STREET & Cul de Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>171'</u>	<u>3-26-97</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>131'</u>			

ENTERS: SIO BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 275' NW. of center of

Patrick Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huxford

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION 15' NE of center of Bridge Stn CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 172214

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY