

LOCATION S13 Bridgestone CT CITY Canton

BETWEEN Patrick Rd STREET & Cal-de-Sk STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|-------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>108'</u> | <u>6-17-97</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>10'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>98'</u> | | | |

ENTERS: S13 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 359' W. of center of Patrick Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. J. Kelly

MAIN-SIZE 2' C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN. LOCATION 41' S. of center of Bridgestone CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 384798

REMARKS



| Test Station | | |
|---|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY