


LOCATION 514 BRIDGESTONE CTCITY GASTONIABETWEEN PATRICK RDSTREET & DEAD END

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>171'</u>	<u>4-1-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>166'</u>			

ENTERS: 514BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 PSI0 INCHES W CLOCATION 377 W of C ofPATRICK RDPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RLMAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1995DEPTH: 3' FT 0 IN. LOCATION 46' W of C of BRIDGESTONE CT."A" P/S READING PLASTICTOTAL ANODES 1# 0 17# 0L.R. # 0195876

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

ENG. DEPT. USE ONLY