

LOCATION 1156 Bridgwood Ln. CITY Castroville

BETWEEN Farmwood Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>124'</u>	<u>4-24-03</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>50'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>74'</u>			

ENTERS 1156 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 46' NW. of center of Farmwood Dr


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.A.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH 3 FT 0 IN LOCATION 27' SE of center of Bridgwood Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 97644

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>-</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	