

LOCATION 624 Bridle Path Tr CITY GASTONIA
BETWEEN Derby Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Cu</u>	<u>133'</u>	<u>Tied over</u> <u>4/23/94</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>Plastic</u>	<u>3'</u>			
PROP. LINE TO BLDG.						

ENTERS: 624 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION East side of 624


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION West side of Bridle Path Tr

"A" P/S READING 1.20 TOTAL ANODES 1* 17 * 0 L.R. #

REMARKS: Tied over 133' of 3/4" Cu service to new main
Ex 3/4" Ins Dresser Banded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.20</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY