

LOCATION 104 Bright Ave CITY Gastonia

BETWEEN Edgewood Rd. STREET & Bright Ave STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------|-------------|------------------|-----------------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>106'</u> | <u>Relocated</u> | <u>11-27-96</u> | |
| MAIN TO PROP. LINE | | | | | | |
| PROP. LINE TO BLDG. | | | | | | |

ENTERS: 104 BRANCHED INTO: 0

TAP SIZE: 3/4 Ser. PRESSURE: 60 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 105 PSI FOR 1 1/4 HRS. BY EP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 1 FT. 6 IN. LOCATION _____

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:

Tinner wire on Riser
bonded to Ext. Clow Service

| Test Station | | |
|---|-----------|------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>Br</u> | <u>1.3</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY

