

LOCATION 134 Bright Ave CITY Easton  
BETWEEN Edgewood STREET & Camden STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Ø</u>	<u>24'</u>	<u>Relocated</u>		
MAIN TO PROP. LINE				<u>10-27-55</u>		
PROP. LINE TO BLDG.						

ENTERS: 134 BRANCHED INTO: NO #

TAP SIZE: 3/4 IN. PRESSURE 60 P.S.I. INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP Lot # 6-5-55


MAIN SIZE 3/4 C.I.     BARE STEEL     COATED STEEL ✓ PLASTIC     YEAR INSTALLED 19

DEPTH: 2 Ft. 6 In. LOCATION

"A" P/S READING 1.2 TOTAL ANODES 1\* Ø17\*Ø L.R. #    

REMARKS:

Tracer line on Plastic Rise Test post, bonded to dress & C/W  
pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic Rise</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY