

LOCATION 142 Bright Ave CITY Gastonia
BETWEEN Gamble Ave STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>18'</u>	<u>10-23-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>18'</u>			

ENTERS: 142 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 111' E. of center of Bright Ave

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBELL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1966
DEPTH: 3 Ft. 0 In. LOCATION 22' S. of center of Gamble Ave

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # 606505

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY