

LOCATION 143 Bright Ave CITY GASTONIA  
BETWEEN Gamble STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	62'	11/4/96		
MAIN TO PROP. LINE	3/4"		10'			
PROP LINE TO BLDG.	3/4"		52'			

ENTERS: 143 BRANCHED INTO:  
TAP SIZE: 3/8" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION North side of 143

PRESSURE TEST: @ 100 PSI FOR 44 HRS BY DT  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1966  
DEPTH: 2 FT. IN 6 LOCATION West side of Bright Ave

"A" P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 L.R. # 62587#

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY