

LOCATION 225 BRIGHT AVE

CITY GASTONIA

BETWEEN GAUMBLE AVE

STREET & TREMONT TRE.

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED ^{Relocated} | RENEWED |
|---------------------|------|------|--------|-----------|---|---------|
| MAIN TO BLDG. | 3/4 | P | 40' | | 5-2-94 | |
| MAIN TO PROP. LINE | | | | | | |
| PROP. LINE TO BLDG. | | | | | | |

ENTERS: 225

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION 103' W. of C of Bright av.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP

MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1976

DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING 1.50 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:



Test Station

ENG. DEPT. USE ONLY

| Reading & Location | Lead | Volts |
|--|-----------|----------|
| P/S Pipeline Lead - Red New Service | <u>OR</u> | <u>P</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |