

LOCATION 402 N. Broad St. CITY Gastonia  
BETWEEN Magnolia St. STREET & Broad St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>		<u>Renewed</u>	<u>Tied Over</u>	<u>12' Existing</u>
MAIN TO PROP. LINE				<u>11-8-95</u>	<u>3/4 Plastic</u>	<u>To New</u>
PROP. LINE TO BLDG.					<u>2" Plastic</u>	<u>Main</u>

ENTERS: 402 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 94' E of C of Broad St.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996  
DEPTH: \_\_\_\_\_ FT \_\_\_\_\_ IN LOCATION 14' N of C of Ratchford Ave.

"A" P/S READING \_\_\_\_\_ Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # N/A

REMARKS:

	Test Station		
	Reading & Location	Lead	Vqlts
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY