

LOCATION	412 1/2 N. BROAD			CITY	East	
BETWEEN	WALNUT			STREET &	Ratchford	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	135'		10 - 21	- 96
MAIN TO PROP. LINE	"	"	0			
PROP. LINE TO BLDG.	"	"	135'			

ENTERS: 412 BRANCHED INTO: 412 1/2

TAP SIZE: 3/4" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION E. of 412 1/2


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GK

MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1987

DEPTH: 1 Ft. 6 In. LOCATION S. side of 412

"A" P/S READING F TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY