

LOCATION 419 N. BROAD St. CITY East.

BETWEEN WALNUT STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	26'		10 - 18	- 96
MAIN TO PROP. LINE	"	"	35'			
PROP. LINE TO BLDG.	"	"	41			

ENTERS: 419 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION N. of 419


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GIL

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 Ft. _____ In. LOCATION E. side of N. BROAD

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY