

LOCATION 504 N. BROAD CITY GAST.

BETWEEN REVERSE CURVE STREET & WALNUT STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	68		10-17	-96
MAIN TO PROP. LINE	"	"	5'			
PROP. LINE TO BLDG.	"	"	63			

ENTERS: 504 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION E. of 504


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GL

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 Ft. In. LOCATION E. of N. BROAD

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY