

LOCATION 513 N Broad CITY Quintonia  
BETWEEN E Walnut STREET & Reverse curve STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>165 exist</u>	<u>12-11-96</u>		
MAIN TO PROP. LINE			<u>4' new 3/4"</u>			
PROP. LINE TO BLDG.			<u>169 Total</u>			

ENTERS: 513 BRANCHED INTO:  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 15' E OF N Broad

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M Parker  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 1996  
DEPTH: 3 FT. 0 IN. LOCATION 251' N OF E WALNUT

"A" P/S READING Q TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.152</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY