

LOCATION 525 N Broad st (Schwarz metal shop) CITY GASTONIA  
BETWEEN E WALNUT STREET & STREET


	SIZE	TYPE	LENGTH	<del>INSTALLED</del>	RETIRED	RENEWED
MAIN TO BLDG.	2"	Plastic	89'	Relocate 10/18/95		
MAIN TO PROP. LINE	2"		89'			
PROP. LINE TO BLDG.	2"		89'			

ENTERS: 525 (Bldg B) BRANCHED INTO:  
TAP SIZE: 1 5/8" PRESSURE 60 P.S.I. INCHES W.C. LOCATION E side of 525

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT  
Service MAIN - SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC   /   YEAR INSTALLED 1992  
DEPTH: 2 Ft. 6 In. LOCATION West side of N Broad st

"A" P/S READING 0 TOTAL ANODES 1\* 0 17\* 0 L.R. #     

REMARKS: 89' OF 2" Plastic Pipe tested with AIP  
At 100" For 1 hr.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY