

LOCATION 528 N. BROAD ST. CITY EAST.

BETWEEN Reverse Curve STREET & Walnut STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>64'</u>		<u>10 - 14 - 96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>59'</u>			

ENTERS: 528 BRANCHED INTO:

TAP SIZE: 3 1/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N. side of 528


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GL

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION E side of Broad

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY