

LOCATION 529 N. Broad CITY East.
BETWEEN Reverse Curve STREET & Walnut STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	88'		10 - 11	-96
MAIN TO PROP. LINE	"	"	35'			
PROP. LINE TO BLDG.	"	"	53'			

ENTERS: 529 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N. of 529


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AK

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION E side of N Broad

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY