

LOCATION 535 Broad St CITY East.

BETWEEN Reverse Curve STREET & WALNUT STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>114'</u>		<u>10 - 10</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>79'</u>			

ENTERS: 535 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE: 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION S. of 535


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION E side of Broad

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>7</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY