

LOCATION 1019 N. Broad st CITY Gastonia
BETWEEN Woodhill STREET & Briarwood STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|-----------|------------|---------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>67'</u> | <u>9-5-96</u> | | |
| MAIN TO PROP. LINE | <u>11</u> | <u>11</u> | <u>19'</u> | | | |
| PROP. LINE TO BLDG. | <u>11</u> | <u>11</u> | <u>48'</u> | | | |

ENTERS: 1019 BRANCHED INTO: —
TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 7' W. of C of
N. Broad st

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GP
MAIN-SIZE 1 1/2" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1956
DEPTH: 2 FT. 6 IN. LOCATION _____

"A" P/S READING .700 TOTAL ANODES 1# _____ 17# 1 L.R. # _____

REMARKS: _____



| Test Station | | |
|--|----------|----------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>R</u> | <u>P</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY