

LOCATION 418 S. Broad. CITY Gastonia
BETWEEN 3rd STREET & 4th STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>30'</u>		<u>Tied over</u>	<u>71' of ext</u>
MAIN TO PROP. LINE				<u>3-4-94</u>	<u>3/4" New Ser. to Ext</u>	<u>2" Plastic</u>
PROP. LINE TO BLDG.					<u>main</u>	

ENTERS: 418 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For 14 Hrs. By EP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Tracer wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY