

LOCATION 1113 Broad St. CITY Gastonia
BETWEEN Woodhill STREET & Briarwood STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>92'</u>		<u>3/4" c&w with</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2'</u>		<u>Main. Purged with</u>	
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>90'</u>		<u>Air + capped</u>	<u>10-9-97</u>

ENTERS: Same

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 15' west of Broad St. +

465' South of Briarwood Ln.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BB

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1981

DEPTH: 3 FT 0 IN LOCATION 15' west of Broad St.

"A" P/S READING 1.2 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Retired & Renewed Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY