

LOCATION 1900 BROADCAST ST. CITY GASTONIA

BETWEEN RANKIN LAKE RD. STREET & Cut-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>	<u>2-17-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>			

ENTERS 1900 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 440' S. of center of RANKIN LAKE RD.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SK

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1979

DEPTH 4 FT 0 IN LOCATION 20' E. of center of Broadcast St.

"A" P/S READING 1.7 TOTAL ANODES 1# 0 17# 0 LR # 118761

REMARKS



Test Station		
Reading & location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	