

LOCATION 1903 Broadcast St CITY Castroville

BETWEEN PANKW LAKE RD. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>227'</u>	<u>7-14-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>217'</u>			

ENTERS 1903 BRANCHED INTO

TAP SIZE 1/8" PRESSURE 60 PSI INCHES W.C. LOCATION 425' S. of center of PANKW Lake Rd


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

PIPE SIZE 1" C I        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1979

DEPTH 3 FT 0 IN LOCATION 18' W of center of Broadcast St

"A" P/S READING 1.6 TOTAL ANODES 1# 0 17# 0 LR # 576268

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	