

LOCATION 2199 Brookneat DR. CITY Bastonia

BETWEEN Fleetwood DR STREET & Rhyne and Cris STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	100'	1-21-03		
MAIN TO PROP LINE	5/8"	P	8'			
PROP LINE TO BLDG	5/8"	P	90'			

ENTERS 2199 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 167' W. of center of Fleetwood Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 4" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1963

DEPTH 3 FT 0 IN LOCATION 12' S. of center of Brookneat DR

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 LR # 20971

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	