

LOCATION 804 Brookside DR CITY Gastonia  
BETWEEN Woodvale LN. STREET & \_\_\_\_\_ ST \_\_\_\_\_

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	$3/4"$	P	120'	2-3-00	120' c/w	
MAIN TO PROP. LINE	$3/4"$	P	50'		purged with Air &	
PROP. LINE TO BLDG	$3/4"$	P	70'		formed 2-3-00	

ENTERS: Same BRANCHED INTO \_\_\_\_\_

TAP SIZE: 1/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 64' East of  
Woodvale LN & 12' South of Brookside DR.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BB

MAIN SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1976

DEPTH: 3 FT 6 IN LOCATION 12' south of Brookside DR

"A" P/S READING 1.1 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Retired & Renewed Service  
TRANstate Const. Broke 3/4" c/w service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	p. Riser
P/S Pipeline Lead - White Existing Main	E	